

Cordex HP Controller Operating System v6.30

Alpha and Outback Energy GmbH is pleased to announce the release of our newest operating system for the Cordex HP Controller, Version 6.30.

NOTE: Reverting to older versions of the OS is not advisable, and can cause unpredictable results, including failure to boot.

New Features and Improvements:

- Improves flash error handling to reduce lock-up issues.
- Reduced read and write errors significantly, speeding up operations (such as booting) by approximately two times.

Upgrade procedures using the LCD:

1. Copy the file "CordexHP.OS.v6.30_0350090-110_L.zip" to a USB 3.0 memory stick, and plug it into the Cordex HP.
2. Login via the Cordex HP LCD interface.
3. Navigate to Shortcuts -> Browse USB
4. Select the upgrade file previously copied to the USB stick
5. On the next screen, click "Execute"
6. The Controller will load the operating system.
7. Reboot the Controller manually to have the changes take effect.

You have now successfully upgraded the Cordex HP Operating System. Thank you for choosing Alpha and Outback Energy GmbH.

Worldwide Corporate Offices

Headquarter Germany

Hansastraße 8
D-91126 Schwabach
Tel: +49 9122 79889 0
Fax: +49 9122 79889 21
Mail: info@alpha-outback-energy.com

Eastern Europe

ee@alpha-outback-energy.com

France and Benelux

fbnl@alpha-outback-energy.com

Africa

africa@alpha-outback-energy.com

Middle East

me@alpha-outback-energy.com

Spain

spain@alpha-outback-energy.com

Alpha and Outback Energy GmbH reserves the right to make changes to the products and information contained in this document without notice. Copyright © 2020 Alpha and Outback Energy GmbH. All Rights reserved.

For more information, please visit www.alpha-outback-energy.com